

Passive Combustion and Ventilation Air Configuration

Based NFPA-54 2006 Section 9.3.3.1 – Vertical pipes with a minimum free area opening of 1 in.² / 4000 Btu/hr total input of the appliances in the space

